

REQUEST FOR PROPOSALS

ADDENDUM #1

Questions and Clarifications

Automatic Vertical Pivot Gate

Proposal # 2020-004

TO: Prospective Proposers
FROM: BCRTA - Ruth Reed, Finance Coordinator
DATE: 7-May-20
SUBJECT: Addendum No.1 - Questions and Clarifications

The following is included as part of Addendum No. 1 and supersedes the language/requirements set forth in the original "RFP".

ADDENDUM #1 - Questions and Clarifications

#	Questions Submitted or Asked	Response from BCRTA
1	I was looking at the scope of work for the pivot gate project and the operators say swing gate operators? We would quote pivot gate operators if that is the type of gate you are wanting?	Yes, we are looking for pivot gate operators.
2	Can I just send our quote to you?	Please follow the directions of the RFP Section 1 -C
3	Is the gate project PW and tax exempt? Not seeing that info anywhere.	Please see the Section 5-S of our RFP in reference to the Davis-Bacon Act. Yes
4	How many feet would conduit have to run to the server room? Is being done by electrician? Because we will need power ran to our operators.	Please look at Section 2-A and Attachment F. The yellow lines in "Attachment F" is where the electric will need to be run by your electrician approx. 300 feet. It is highly recommended that bidders field verify for exact dimensions.
5	I also need to know what type of fence is existing to match. flush or picket bottom flush, picket, or spear top?	Our current chain link fence is flush on the bottom and picket at the top. As far as the new fencing, pivot gates, passenger gate and above the operators, we would prefer flush across the top.